

red dye installation

The dye tablets are inserted into the filter strainers of the chiller or IFP. Typically one to two tablets are used.

NOTE: One tablet is good for up to 60 gallons of glycol in the system. An additional tablet is required for systems with more than 60 gallons.

Tablets will dissolve in 5 minutes.

HANDLING: When handling the dyes, gloves will need to be used.

